



464 Valley Brook Avenue, Lyndhurst NJ 07071
129 Sea Girt Avenue, Manasquan NJ 08736
Phone: (800) 423-0766 • Fax: (201) 438-1798
www.mccabeenv.com

LEAD IN DRINKING WATER TESTING REPORT

Conducted for:

Beloved Community Charter School
508 Grand Street
Jersey City, New Jersey 07302

Conducted at:

Beloved Community Charter School
508 Grand Street
Jersey City, New Jersey 07302

Submitted by:

McCabe Environmental Services, L.L.C.
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

REPORT DATE: December 9, 2021

MES PROJECT NO.: 21-04229

Prepared by:

A handwritten signature in black ink that reads 'Luke Giunta'.

Luke Giunta
Environmental Scientist

Signed for the Company by:

A handwritten signature in blue ink that reads 'John H. Chiaviello'.

John H. Chiaviello
Vice President

TABLE OF CONTENTS

	<u>Page</u>
1.0 INTRODUCTION	1
2.0 SCOPE OF WORK.....	1
3.0 PROCEDURES.....	1
4.0 TABLE OF SAMPLE RESULTS	2
5.0 DISCUSSION AND CONCLUSION	3

APPENDIX A

Laboratory Certificates of Analysis
&
Sample Chain of Custody Forms

1.0 INTRODUCTION

McCabe Environmental Services, L.L.C. (McCabe) was retained by Beloved Community Charter School (Client) to conduct lead in drinking water testing at 508 Grand Street, Jersey City, New Jersey 07302.

The project information is as follows:

Client Name: Beloved Community Charter School

Contact Person: Mr. Duane Moeller

Project Name: Beloved Community Charter School – Lead in Drinking Water Testing

Project Location: 508 Grand Street
Jersey City, New Jersey 07302

Date(s) of Service: November 23, 2021

McCabe Personnel: Gary Clare & Luke Giunta

2.0 SCOPE OF WORK

Drinking water testing was performed at 508 Grand Street, Jersey City, New Jersey 07302 on November 23, 2021. The testing was limited to the Main Building and Annex of the Beloved Community Charter School. The purpose of the testing was to determine if the building's plumbing was having an adverse impact on water quality, specifically with regard to lead concentrations. Samples were collected from various potential drinking water outlets located throughout the building.

3.0 PROCEDURES

After determining which outlets would be sampled, McCabe personnel collected a "first draw" sample at each location. A "first draw" is the initial water that is first to come out of the tap after a period of inactivity. All samples were collected into 250 mL sterile bottles, labeled with a sample identification, and analyzed in accordance with EPA approved methods to determine the level of lead in drinking water. Samples were analyzed by an accredited laboratory.

The U.S. Environmental Protection Agency (EPA) has established National Primary Drinking Water Regulations (NPDWR) that set mandatory water quality standards for drinking water contaminants. These are enforceable standards called "maximum contaminant levels" or "MCL", which are established to protect the public against consumption of drinking water contaminants that present a risk to human health. An MCL is the maximum allowable amount of a contaminant in drinking water which is delivered to the consumer.

The EPA has established the Lead and Copper Rule that sets standards for state and public water systems. This rule has set an MCL for lead at 15 parts per billion (ppb) for a one liter sample. However, the EPA also established the Lead in Drinking Water at Schools and Child Care Facilities in which the EPA recommends an MCL of 20 ppb for a 250 milliliter first draw sample. In order to be more stringent, for our report purposes we have compared all results to both the 15 ppb and the 20 ppb standards.

4.0 TABLE OF SAMPLE RESULTS

The following table presents all sample results in order of sample identification:

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
01	Main Building 1 st Floor Girl's Room Left Sink	2.6	Pass	Pass
02	Main Building 1 st Floor Girl's Room Left Sink 30 Second Flush	0.9	Pass	Pass
03	Main Building 1 st Floor Girl's Room Right Sink	1.1	Pass	Pass
04	Main Building 1 st Floor Boy's Room Middle Sink	< 0.5	Pass	Pass
05	Main Building 1 st Floor Staff Bathroom	< 0.5	Pass	Pass
06	Main Building 1 st Floor Bottle Water Fountain	< 0.5	Pass	Pass
07	Main Building 1 st Floor Cafeteria Bottle Water Fountain	0.7	Pass	Pass
08	Main Building 1 st Floor Multipurpose Room Bottle Water Fountain	< 0.5	Pass	Pass
09	Main Building 1 st Floor Kitchen Food Prep Sink	< 0.5	Pass	Pass
10	Main Building 1 st Floor Kitchen Handwashing Sink	0.6	Pass	Pass
11	Main Building 2 nd Floor Girl's Room Middle Sink	< 0.5	Pass	Pass
12	Main Building 2 nd Floor Staff Bathroom Sink	< 0.5	Pass	Pass
13	Main Building 2 nd Floor Boy's Room Left Sink	< 0.5	Pass	Pass
14	Annex 3 rd Floor Bottle Water Fountain	< 0.5	Pass	Pass
15	Annex 3 rd Floor Girl's Bathroom Right Sink	< 0.5	Pass	Pass
16	Annex 3 rd Floor Boy's Bathroom Left Sink	< 0.5	Pass	Pass
17	Annex 3 rd Floor Staff Bathroom Sink	< 0.5	Pass	Pass

Sample ID	Sample Location	Lead Result	Exceeds (MCL 15 ppb)	Exceeds (MCL 20 ppb)
18	Annex 2 nd Floor Girl's Bathroom Left Sink	< 0.5	Pass	Pass
19	Annex 2 nd Floor Bottle Water Fountain	< 0.5	Pass	Pass
20	Annex 2 nd Floor Boy's Bathroom Left Sink	< 0.5	Pass	Pass
21	Annex 1 st Floor Girl's Bathroom Right Sink	< 0.5	Pass	Pass
22	Annex 1 st Floor Boy's Bathroom Right Sink	< 0.5	Pass	Pass
23	Annex 1 st Floor Cafeteria Water Fountain	< 0.5	Pass	Pass
24	Annex 1 st Floor Kitchen Food Prep Sink	< 0.5	Pass	Pass

5.0 DISCUSSION AND CONCLUSION

A total of twenty-four (24) samples were collected from Main Building and Annex of the Beloved Community Charter School. All samples were found to be less than the EPA Lead in Drinking Water at Schools and Child Care Facilities standard of 20 ppb, as well as the EPA Lead and Copper Rule standard of 15 ppb.

In addition, McCabe Environmental recommends annual drinking water sampling to ensure that the building's plumbing is not having an adverse impact on water quality.

APPENDIX A

**LABORATORY CERTIFICATES OF ANALYSIS
&
SAMPLE CHAIN OF CUSTODY FORMS**



Thursday, December 02, 2021

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
SDG ID: GCJ84879
Sample ID#s: CJ84879 - CJ84902

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory. This report is incomplete unless all pages indicated in the pagination at the bottom of the page are included.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Sincerely yours,

A handwritten signature in black ink, appearing to read "Phyllis Shiller".

Phyllis Shiller

Laboratory Director

NELAC - #NY11301
CT Lab Registration #PH-0618
MA Lab Registration #M-CT007
ME Lab Registration #CT-007
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003
NY Lab Registration #11301
PA Lab Registration #68-03530
RI Lab Registration #63
UT Lab Registration #CT00007
VT Lab Registration #VT11301



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Sample Id Cross Reference

December 02, 2021

SDG I.D.: GCJ84879

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH

Client Id	Lab Id	Matrix
01	CJ84879	DRINKING WATER
02	CJ84880	DRINKING WATER
03	CJ84881	DRINKING WATER
04	CJ84882	DRINKING WATER
05	CJ84883	DRINKING WATER
06	CJ84884	DRINKING WATER
07	CJ84885	DRINKING WATER
08	CJ84886	DRINKING WATER
09	CJ84887	DRINKING WATER
10	CJ84888	DRINKING WATER
11	CJ84889	DRINKING WATER
12	CJ84890	DRINKING WATER
13	CJ84891	DRINKING WATER
14	CJ84892	DRINKING WATER
15	CJ84893	DRINKING WATER
16	CJ84894	DRINKING WATER
17	CJ84895	DRINKING WATER
18	CJ84896	DRINKING WATER
19	CJ84897	DRINKING WATER
20	CJ84898	DRINKING WATER
21	CJ84899	DRINKING WATER
22	CJ84900	DRINKING WATER
23	CJ84901	DRINKING WATER
24	CJ84902	DRINKING WATER



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:10
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84879

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 01

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	2.6	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:14
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84880

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 02

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.9	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:16
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84881

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 03

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	1.1	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:18
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84882

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 04

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date

11/23/21 7:20
11/23/21 17:18

Time

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84883

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 05

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:21
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84884

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 06

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date

11/23/21 7:22
11/23/21 17:18

Time

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84885

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 07

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.7	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date

11/23/21 7:25
11/23/21 17:18

Time

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84886

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 08

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:27
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84887

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 09

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date

11/23/21 7:27
11/23/21 17:18

Time

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84888

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.6	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:30
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84889

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date

11/23/21 7:31
11/23/21 17:18

Time

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84890

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:31
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84891

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 13

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:35
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84892

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 14

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date

11/23/21 7:35
11/23/21 17:18

Time

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84893

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 15

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:36
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84894

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 16

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date

11/23/21 7:36
11/23/21 17:18

Time

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84895

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 17

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date

11/23/21 7:37
11/23/21 17:18

Time

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84896

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 18

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:37
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84897

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 19

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date

11/23/21 7:38
11/23/21 17:18

Time

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84898

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 20

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:38
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84899

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 21

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date

11/23/21 7:39
11/23/21 17:18

Time

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84900

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 22

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date Time

11/23/21 7:41
11/23/21 17:18

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84901

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 23

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Report

December 02, 2021

FOR: Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071

Sample Information

Matrix: DRINKING WATER
Location Code: MCCABE-PB
Rush Request: Standard
P.O.#: 21-04229

Custody Information

Collected by:
Received by: B
Analyzed by: see "By" below

Date

11/23/21 7:43
11/23/21 17:18

Time

Laboratory Data

SDG ID: GCJ84879
Phoenix ID: CJ84902

Project ID: 21-04229 BELOVED COMMUNITY CHARTER SCH
Client ID: 24

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.5	0.5	2	ppb	15			11/30/21	CPP	E200.8
Total Metal Digestion	Completed							11/29/21	AG	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

December 02, 2021

Reviewed and Released by: Rashmi Makol, Project Manager

Analysis Report - Summary

December 02, 2021

Attn: Jarred Panecki
McCabe Environmental Services, LLC
464 Valley Brook Avenue
Lyndhurst, New Jersey 07071



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

SDG I.D.: GCJ84879



Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
Project: 21-04229 Beloved Community Charter Sch								
CJ84879	01	11/23/21	Lead	2.6	0.5	ppb	11/30/21	E200.8
CJ84880	02	11/23/21	Lead	0.9	0.5	ppb	11/30/21	E200.8
CJ84881	03	11/23/21	Lead	1.1	0.5	ppb	11/30/21	E200.8
CJ84882	04	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84883	05	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84884	06	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84885	07	11/23/21	Lead	0.7	0.5	ppb	11/30/21	E200.8
CJ84886	08	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84887	09	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84888	10	11/23/21	Lead	0.6	0.5	ppb	11/30/21	E200.8
CJ84889	11	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84890	12	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84891	13	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84892	14	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84893	15	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84894	16	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84895	17	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84896	18	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84897	19	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84898	20	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84899	21	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84900	22	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84901	23	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8
CJ84902	24	11/23/21	Lead	< 0.5	0.5	ppb	11/30/21	E200.8

Sample	Client Id	Col Date	Parameter	Result	RL	Units	Date Analyzed	Reference
--------	-----------	-------------	-----------	--------	----	-------	------------------	-----------

Comments:

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

ND=Not detected BDL=Below Detection Level RL=Reporting Level CL=Client Limit



Phyllis Shiller
Laboratory Director
December 02, 2021



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



QA/QC Report

December 02, 2021

QA/QC Data

SDG I.D.: GCJ84879

Parameter	Blank	Blk RL	Sample Result	Dup Result	Dup RPD	LCS %	LCSD %	LCS RPD	MS %	MSD %	MS RPD	% Rec Limits	% RPD Limits
-----------	-------	-----------	------------------	---------------	------------	----------	-----------	------------	---------	----------	-----------	--------------------	--------------------

QA/QC Batch 602326 (mg/L), QC Sample No: CJ84704 2X (CJ84879)

ICP MS Metals - Aqueous

Lead	BRL	0.0001	<0.0005	<0.0001	NC	105						95.6	
------	-----	--------	---------	---------	----	-----	--	--	--	--	--	------	--

QA/QC Batch 602326A (mg/L), QC Sample No: CJ84880 2X (CJ84880, CJ84881, CJ84882, CJ84883, CJ84884, CJ84885, CJ84886, CJ84887, CJ84888, CJ84889)

ICP MS Metals - Aqueous

Lead	BRL	0.0001				105						99.6	
------	-----	--------	--	--	--	-----	--	--	--	--	--	------	--

Comment:

This batch does not include a duplicate.

QA/QC Batch 602327 (mg/L), QC Sample No: CJ84890 2X (CJ84890, CJ84891, CJ84892, CJ84893, CJ84894, CJ84895, CJ84896, CJ84897, CJ84898, CJ84899)

ICP MS Metals - Aqueous

Lead	BRL	0.0001	<0.0005	0.0003	NC	105						95.4	
------	-----	--------	---------	--------	----	-----	--	--	--	--	--	------	--

QA/QC Batch 602327A (mg/L), QC Sample No: CJ84900 2X (CJ84900, CJ84901, CJ84902)

ICP MS Metals - Aqueous

Lead	BRL	0.0001				105						99.2	
------	-----	--------	--	--	--	-----	--	--	--	--	--	------	--

Comment:

This batch does not include a duplicate.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

RPD - Relative Percent Difference
LCS - Laboratory Control Sample
LCSD - Laboratory Control Sample Duplicate
MS - Matrix Spike
MS Dup - Matrix Spike Duplicate
NC - No Criteria
Intf - Interference

Phyllis Shiller, Laboratory Director
December 02, 2021

Criteria: NJ: DW
State: NJ

Sample Criteria Exceedances Report
GCJ84879 - MCCABE-PB

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823



Analysis Comments

December 02, 2021

SDG I.D.: GCJ84879

The following analysis comments are made regarding exceptions to criteria not already noted in the Analysis Report or QA/QC Report: None.

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER CHAIN-OF-CUSTODY FORM

NCNC
20.3

CLIENT NAME: Beloved Community Charter School		SITE ADDRESS: 508 Grand Street, Jersey City, New Jersey 07302	
FIELD INSPECTOR'S NAME: Gary Clare & Luke Giunta		TURNAROUND TIME REQUESTED:	
MES PROJECT #: 21-04229		SAMPLE DATE: 11/23/2021	
SAMPLE LOCATION		ANALYSIS REQUESTED	
Matrix	SAMPLE ID	TIME COLLECTED	ANALYSIS REQUESTED
DW	01 848879	Main Building 1st Floor Girl's Room Left Sink	7:10 AM
DW	02 848880	Main Building 1st Floor Girl's Room Left Sink 30 Second Flush	7:14 AM
DW	03 848881	Main Building 1st Floor Girl's Room Right Sink	7:16 AM
DW	04 848882	Main Building 1st Floor Boy's Room Middle Sink	7:18 AM
DW	05 848883	Main Building 1st Floor Staff Bathroom	7:20 AM
DW	06 848884	Main Building 1st Floor Bottle Water Fountain	7:21 AM
DW	07 848885	Main Building 1st Floor Locker Room Bottle Water Fountain	7:22 AM
DW	08 848886	Main Building 1st Floor Multipurpose Room Bottle Water Fountain	7:25 AM
DW	09 848887	Main Building 1st Floor Kitchen Food Prep Sink	7:27 AM
DW	10 848888	Main Building 1st Floor Kitchen Handwashing Sink	7:27 AM
Relinquished by (Print) Luke Giunta		Date: 11/23/2021 Time: 11:20	
Signature: <i>Luke Giunta</i>		Received by: (Print) <i>Sam</i> Signature: <i>Sam</i>	
Relinquished by (Print)		Date: 11/23/2021 Time: 1718	
Signature: <i>Sam</i>		Received by: (Print) <i>Sam</i> Signature: <i>Sam</i>	
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories			

NJ Certified WBE

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798







NCNC
20.3

LEAD in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Beloved Community Charter School		SITE ADDRESS: 508 Grand Street, Jersey City, New Jersey 07302	
FIELD INSPECTOR'S NAME: Gary Clare & Luke Giunta		TURNAROUND TIME REQUESTED:	
MES PROJECT #: 21-04229	SAMPLE DATE: 11/23/2021	2 week 7AT	

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	11 84889	Main Building 2nd Floor Girl's Room Middle Sink	7:30 AM	LEAD - 200.8
DW	12 84890	Main Building 2nd Floor Staff Bathroom Sink	7:31 AM	LEAD - 200.8
DW	13 84891	Main Building 2nd Floor Boy's Room Left Sink	7:31 AM	LEAD - 200.8
DW	14 84892	Annex 3rd Floor Bottle Water Fountain	7:35 AM	LEAD - 200.8
DW	15 84893	Annex 3rd Floor Girl's Bathroom Right Sink	7:35 AM	LEAD - 200.8
DW	16 84894	Annex 3rd Floor Boy's Bathroom Left Sink	7:36 AM	LEAD - 200.8
DW	17 84895	Annex 3rd Floor Staff Bathroom Sink	7:36 AM	LEAD - 200.8
DW	18 84896	Annex 2nd Floor Girl's Bathroom Left Sink	7:37 AM	LEAD - 200.8
DW	19 84897	Annex 2nd Floor Bottle Water Fountain	7:37 AM	LEAD - 200.8
DW	20 84898	Annex 2nd Floor Boy's Bathroom Left Sink	7:38 AM	LEAD - 200.8

Relinquished by (Print) Luke Giunta	Date: 11/23/2021	Time: 11:20
Signature: 	Received by: (Print) 	Signature: 
Relinquished by (Print)	Date:	Time:
Signature: 	Received by: (Print) 	Signature: 

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

NJ Certified WBE

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

LEAD in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Beloved Community Charter School		SITE ADDRESS: 508 Grand Street, Jersey City, New Jersey 07302	
FIELD INSPECTOR'S NAME: Gary Clare & Luke Giunta		TURNAROUND TIME REQUESTED:	
MES PROJECT #: 21-04229		2 week 197	
SAMPLE DATE: 11/23/2021			
Matrix	SAMPLE ID	SAMPLE LOCATION	ANALYSIS REQUESTED
DW	21 84899	Annex 1st Floor Girl's Bathroom Right Sink	LEAD - 200.8
DW	22 84900	Annex 1st Floor Boy's Bathroom Right Sink	LEAD - 200.8
DW	23 84901	Annex 1st Floor Cafeteria Water Fountain	LEAD - 200.8
DW	24 84902	Annex 1st Floor Kitchen Food Prep Sink	LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
DW			LEAD - 200.8
Relinquished by (Print) Luke Giunta		Received by: (Print) zee	Date: 11/23/21 Time: 11:20
Signature: Luke Giunta		Signature:	
Relinquished by (Print)		Received by: (Print)	Date: 11/23 Time: 1718
Signature: Gary		Signature:	
Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories			

NJ Certified WBE

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

NCNC
20.3

LEAD in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Beloved Community Charter School

SITE ADDRESS: 508 Grand Street, Jersey City, New Jersey 07302

FIELD INSPECTOR'S NAME: Gary Clare & Luke Giunta

TURNAROUND TIME REQUESTED:

MES PROJECT #: 21-04229

SAMPLE DATE: 11/23/2021

2 week TAT

Matrix	SAMPLE ID	SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	01 84879	Main Building 1st Floor Girl's Room Left Sink	7:10 AM	LEAD - 200.8
DW	02 84880	Main Building 1st Floor Girl's Room Left Sink 30 Second Flush	7:14 AM	LEAD - 200.8
DW	03 84881	Main Building 1st Floor Girl's Room Right Sink	7:16 AM	LEAD - 200.8
DW	04 84882	Main Building 1st Floor Boy's Room Middle Sink	7:18 AM	LEAD - 200.8
DW	05 84883	Main Building 1st Floor Staff Bathroom	7:20 AM	LEAD - 200.8
DW	06 84884	Main Building 1st Floor Bottle Water Fountain	7:21 AM	LEAD - 200.8
DW	07 84885	Main Building 1st Floor Cafeteria Bottle Water Fountain	7:22 AM	LEAD - 200.8
DW	08 84886	Main Building 1st Floor Multipurpose Room Bottle Water Fountain	7:25 AM	LEAD - 200.8
DW	09 84887	Main Building 1st Floor Kitchen Food Prep Sink	7:27 AM	LEAD - 200.8
DW	10 84888	Main Building 1st Floor Kitchen Handwashing Sink	7:27 AM	LEAD - 200.8

Relinquished by (Print) Luke Giunta

Date:

Time:

11/23/2021

11:20

Received by: (Print) Zeeck

Date:

Time:

11/23/21

11:20

Signature:

Luke Giunta

Signature:

[Signature]

Relinquished by (Print)

Date:

Time:

Received by: (Print)

Date:

Time:

Signature:

[Signature]

Signature:

[Signature]

11/23

1718

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

MCCABE ENVIRONMENTAL SERVICES, L.L.C.

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

 NCNC
20.3

LEAD in DRINKING WATER
CHAIN-OF-CUSTODY FORM
CLIENT NAME: Beloved Community Charter School

SITE ADDRESS: 508 Grand Street, Jersey City, New Jersey 07302

FIELD INSPECTOR'S NAME: Gary Clare & Luke Giunta

TURNAROUND TIME REQUESTED:
MES PROJECT #: 21-04229

SAMPLE DATE: 11/23/2021

2 week TAT

Matrix	SAMPLE ID		SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	11	84889	Main Building 2nd Floor Girl's Room Middle Sink	7:30 AM	LEAD - 200.8
DW	12	84890	Main Building 2nd Floor Staff Bathroom Sink	7:31 AM	LEAD - 200.8
DW	13	84891	Main Building 2nd Floor Boy's Room Left Sink	7:31 AM	LEAD - 200.8
DW	14	84892	Annex 3rd Floor Bottle Water Fountain	7:35 AM	LEAD - 200.8
DW	15	84893	Annex 3rd Floor Girl's Bathroom Right Sink	7:35 AM	LEAD - 200.8
DW	16	84894	Annex 3rd Floor Boy's Bathroom Left Sink	7:36 AM	LEAD - 200.8
DW	17	84895	Annex 3rd Floor Staff Bathroom Sink	7:36 AM	LEAD - 200.8
DW	18	84896	Annex 2nd Floor Girl's Bathroom Left Sink	7:37 AM	LEAD - 200.8
DW	19	84897	Annex 2nd Floor Bottle Water Fountain	7:37 AM	LEAD - 200.8
DW	20	84898	Annex 2nd Floor Boy's Bathroom Left Sink	7:38 AM	LEAD - 200.8

Relinquished by (Print) <i>Luke Giunta</i>	Date: 11/23/2021	Time: 11:20	Received by (Print) <i>Zeel</i>	Date: 11/23/21	Time: 11:20
Signature: <i>Luke Giunta</i>			Signature: <i>[Signature]</i>		
Relinquished by (Print)	Date:	Time:	Received by (Print)	Date: 11/23	Time: 1718
Signature: <i>[Signature]</i>			Signature: <i>[Signature]</i>		

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

McCabe Environmental Services, L.L.C.

464 VALLEY BROOK AVENUE LYNDHURST, NJ 07071 • PHONE: (201)438-4839 FAX: (201)438-1798

WCNC
20.3

LEAD in DRINKING WATER

CHAIN-OF-CUSTODY FORM

CLIENT NAME: Beloved Community Charter School

SITE ADDRESS: 508 Grand Street, Jersey City, New Jersey 07302

FIELD INSPECTOR'S NAME: Gary Clare & Luke Giunta

TURNAROUND TIME REQUESTED:

MES PROJECT #: 21-04229

SAMPLE DATE: 11/23/2021

2 week TAT

Matrix	SAMPLE ID		SAMPLE LOCATION	TIME COLLECTED	ANALYSIS REQUESTED
DW	21	84899	Annex 1st Floor Girl's Bathroom Right Sink	7:38 AM	LEAD - 200.8
DW	22	84900	Annex 1st Floor Boy's Bathroom Right Sink	7:39 AM	LEAD - 200.8
DW	23	84901	Annex 1st Floor Cafeteria Water Fountain	7:41 AM	LEAD - 200.8
DW	24	84902	Annex 1st Floor Kitchen Food Prep Sink	7:43 AM	LEAD - 200.8
DW					LEAD - 200.8
DW					LEAD - 200.8
DW					LEAD - 200.8
DW					LEAD - 200.8
DW					LEAD - 200.8
DW					LEAD - 200.8

Relinquished by (Print) Luke Giunta	Date: 11/23/2021	Time: 11:20	Received by (Print) Zeel	Date: 11/23/21	Time: 11:20
Signature: Luke Giunta			Signature: [Signature]		
Relinquished by (Print)	Date:	Time:	Received by (Print)	Date:	Time:
Signature: [Signature]			Signature: [Signature]	11/23	1718

Laboratory Analysis Performed by (Analyst Signature, Laboratory Name & Location): Phoenix Environmental Laboratories

Attachment A - List of Priority for Sampling

SCHOOL NAME	DATE OF SAMPLING	CERTIFIED LABORATORY	NOTES
Beloved Community Charter School	11/23/2021	Phoenix	

Attachment B – Plumbing Profile

Note: Complete for each school. For additional information see the USEPA publication, “The 3Ts for Reducing Lead in Drinking Water in Schools”

Name of School: Beloved Community Charter School

Grade Levels: K-10

Address: 508 Grand Street, Jersey City, New Jersey 07302

Individual school project officer Signature: Duanne Moeller

Date: 11/23/21

Questions	Answers	
Background Information		
1. What year was the original building constructed? Were any buildings or additions added to the original facility?	Main: 2000 Annex: 2014	Middle School: 2017 High School: 2019 New MPR: 2021
2. If the building was constructed or repaired after 1986, was lead-free plumbing and solder utilized? What type of solder was used? Document all locations where lead solder was used.		
3. Where are the most recent plumbing repairs and replacements?	Location: New MPR Annex: Replaced Kitchen Water Heater	Description: Added MPR, only one Plumbing fixture. Water fountain.
4. With what materials is the service connection (the pipe that carries water to the school from the public water system's main in the street) made? Where is the Service Line located? (This is the POE location.)	Material: Galvanized pipe (Presumed) Location: Comes into Building from Grand Street at Front of Building.	
5. Is there point of entry (POE) or point of use (POU) treatment in use?	Y / (N) Type:	Location:

Questions	Answers
6. Are there tanks in your plumbing system (pressure tanks, gravity storage tanks)?	<input checked="" type="radio"/> Y / N
7. Does the school have a filter maintenance and operation program? If so, who is responsible for this program? What is the process for adding filters?	Only for the water fountains and High School Kitchen. Water fountain filters are replaced when the light comes on. High School filters on ice maker and steamer are replaced every six months.
8. Have accessible screens or aerators on outlets that provide drinking water been cleaned? Does the school have a screen or aerator maintenance program?	Y / <input checked="" type="radio"/> N
9. Have there been any complaints about bad (metallic) taste? Note location(s).	Y / <input checked="" type="radio"/> N Location:
10. Review records and consult with the public water supplier to determine whether any water samples have been taken in the building for any contaminants. If so, identify: <ul style="list-style-type: none"> • Name of contaminant(s) • Concentrations found • pH level Is testing done regularly at the building?	
11. Other plumbing background questions include: <ul style="list-style-type: none"> • Are blueprints of the building available? • Are there known plumbing “dead-ends”, low use areas, existing leaks or other “problem areas”? Are renovations planned for any of the plumbing system?	Blueprints are available. There are no know “dead-ends” in the system. No plumbing renovations are planned.

Questions	Answers
Walk-Through <i>These questions should be addressed during the walk-through of the facility, while Attachment C- Drinking Water Outlet Inventory is being completed.</i>	
1. Confirm the material of Service Line visually.	N/A
2. Confirm the presence of POE or POU treatment.	N/A
3. What are the potable water pipes made of in your facility? <ul style="list-style-type: none"> • Lead • Plastic • Galvanized Metal • Cast Iron • Copper • Other Note the water flow through the building and the areas that receive water first, and which areas receive water last.	N/A
4. Are electrical wires grounded to Water Pipes? Note location(s).	<div>Y / (N)</div> <div>N/A</div> <div>Location:</div>
5. Are brass fittings, faucets, or valves used in your drinking water system? Note that most faucets are brass on the inside. Document the locations of any brass water outlet to be sampled.	Complete in “Brass” Column in Attachment C- Water Outlet Inventory.
6. Locate all drinking water outlets (i.e. water coolers, bubblers, ice machines, kitchen/ food prep sinks, etc.) in the facility.	Complete in Attachment C-Water Outlet Inventory.

Questions	Answers	
<p>7. Have the brands and models of the water coolers in the school been compared to the list of recalled water coolers in the Toolkit?</p> <p>Recalled Drinking Water Fountains</p> <p>Make and Model</p>	<p><input checked="" type="radio"/> / N</p> <p>N/A</p> <p>Type</p>	
<p>8. Have signs of corrosion, such as frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry been detected?</p> <p>Note the locations of water outlets.</p>	<p>Complete in "Signs of Corrosion" column in Attachment C- Drinking Water Outlet Inventory.</p>	
<p>9. Are there any outlets that are not operational and therefore out of service? Permanently? Temporarily?</p> <p>Permanently</p> <p>Temporarily</p>	<p>Y / N</p> <p>Complete "Operational Column" in Attachment C- Drinking Water Outlet Inventory.</p> <p>Type/ Location</p>	<p>Description</p>

Attachment C – Drinking Water Outlet Inventory

Name of School: Beloved Community Charter School

Address: 508 Grand Street, Jersey City, New Jersey 07302

Grade Levels: Elementary

Year School Constructed: 2000 & 2014

Renovated/Additions: N/A

Individual school project officer Name/Signature: Duanne Moeller

Date Completed: 12/01/2021

# ¹	Type	Location	Code	Operational ² (Y/N)	Signs of Corrosion ³ (Y/N)	Filter ⁴ (Y/N)	Brass Fittings, Faucets or valves? (Y/N)	Aerator/ Screen (Y/N)	Motion Activated (Y/N)	Chiller (Y/N)	Water Cooler		Comments
											Make	Model	
01	Sink	Main Building 1 st Floor Girl's Room Left Sink	NA	Y	N	N	N	Y	N	N	NA	NA	
02	Sink	Main Building 1 st Floor Girl's Room Left Sink 30 Second Flush	NA	Y	N	N	N	Y	N	N	NA	NA	
03	Sink	Main Building 1 st Floor Girl's Room Right Sink	NA	Y	N	N	N	Y	N	N	NA	NA	
04	Sink	Main Building 1 st Floor Boy's Room Middle Sink	NA	Y	N	N	N	Y	N	N	NA	NA	

¹ Number outlets starting at the closest outlet to the Point of Entry (POE).

² Document if permanently or temporarily out of service on the Attachment B- Plumbing Profile.

³ Signs of corrosion detected, such as but not limited to frequent leaks, rust-colored water, or stained fixtures, dishes, or laundry.

⁴ Document on Attachment D- Filter Inventory.

05	Sink	Main Building 1 st Floor Staff Bathroom	NA	Y	N	N	N	Y	N	N	NA	NA	
06	Fountain	Main Building 1 st Floor Bottle Water Fountain	NA	Y	N	Y	N	N	Y	Y	Elkay	LZSTL8 WSSP	
07	Fountain	Main Building 1 st Floor Cafeteria Bottle Water Fountain	NA	Y	N	Y	N	N	Y	Y	Elkay	LZSTL8 WSSP	
08	Fountain	Main Building 1 st Floor Multipurpose Room Bottle Water Fountain	NA	Y	N	Y	N	N	Y	Y	Elkay	LZSTL8 WSSP	
09	Sink	Main Building 1 st Floor Kitchen Food Prep Sink	NA	Y	N	N	N	N	N	N	NA	NA	
10	Sink	Main Building 1 st Floor Kitchen Handwashing Sink	NA	Y	N	N	N	N	N	N	NA	NA	
11	Sink	Main Building 2 nd Floor Girl's Room Middle Sink	NA	Y	N	N	N	Y	N	N	NA	NA	
12	Sink	Main Building 2 nd Floor Staff Bathroom Sink	NA	Y	N	N	N	Y	N	N	NA	NA	
13	Sink	Main Building 2 nd Floor Boy's Room Left Sink	NA	Y	N	N	N	Y	N	N	NA	NA	
14	Fountain	Annex 3 rd Floor Bottle Water Fountain	NA	Y	N	Y	N	N	Y	Y	Elkay	LZSTL8 WSSP	
15	Sink	Annex 3 rd Floor Girl's Bathroom Right Sink	NA	Y	N	N	N	Y	N	N	NA	NA	

16	Sink	Annex 3 rd Floor Boy's Bathroom Left Sink	NA	Y	N	N	N	Y	N	N	NA	NA	
17	Sink	Annex 3 rd Floor Staff Bathroom Sink	NA	Y	N	N	N	Y	N	N	NA	NA	
18	Sink	Annex 2 nd Floor Girl's Bathroom Left Sink	NA	Y	N	N	N	Y	N	N	NA	NA	
19	Fountain	Annex 2 nd Floor Bottle Water Fountain	NA	Y	N	Y	N	N	Y	Y	Elkay	LZSTL8 WSSP	
20	Sink	Annex 2 nd Floor Boy's Bathroom Left Sink	NA	Y	N	N	N	Y	N	N	NA	NA	
21	Sink	Annex 1 st Floor Girl's Bathroom Right Sink	NA	Y	N	N	N	Y	N	N	NA	NA	
22	Sink	Annex 1 st Floor Boy's Bathroom Right Sink	NA	Y	N	N	N	Y	N	N	NA	NA	
23	Fountain	Annex 1 st Floor Cafeteria Water Fountain	NA	Y	N	Y	N	N	Y	Y	Elkay	LZSTL8 WSSP	
24	Sink	Annex 1 st Floor Kitchen Food Prep Sink	NA	Y	N	N	N	N	N	N	NA	NA	

Attachment D - Filter InventoryName of School: Beloved Community Charter School Grade Levels: ElementaryAddress: 508 Grand Street, Jersey City, New Jersey 07302Individual School Project Officer Signature: Duanne Moeller Date: 12/01/2021

Sample Location / Code	Brand	Type (Make & Model)	Date Installed or Replaced	Replacement Frequency	NSF Certified for Lead Reduction Y/N
01	Zurn	NA	NA	NA	NA
02	Zurn	NA	NA	NA	NA
03	Zurn	NA	NA	NA	NA
04	Zurn	NA	NA	NA	NA
05	Zurn	NA	NA	NA	NA
06	Elkay	LZSTL8 WSSP	NA	NA	NA
07	Elkay	LZSTL8 WSSP	NA	NA	NA
08	Elkay	LZSTL8 WSSP	NA	NA	NA
09	NA	NA	NA	NA	NA
10	NA	NA	NA	NA	NA
11	Zurn	NA	NA	NA	NA
12	Zurn	NA	NA	NA	NA
13	Zurn	NA	NA	NA	NA
14	Elkay	LZSTL8 WSSP	NA	NA	NA
15	Zurn	NA	NA	NA	NA
16	Zurn	NA	NA	NA	NA
17	Zurn	NA	NA	NA	NA
18	Zurn	NA	NA	NA	NA
19	Elkay	LZSTL8 WSSP	NA	NA	NA
20	Zurn	NA	NA	NA	NA
21	Zurn	NA			

Beloved Community Charter School Sampling Plan

Date: 12/01/2021

22	Zurn	LZSTL8 WSSP			
23	Elkay				
24	NA	NA			

Attachment E – Flushing LogName of School: Beloved Community Charter SchoolAddress: 508 Grand Street, Jersey City, New Jersey 07302Grade Levels: ElementaryIndividual School Project Officer Signature: Duanne MoellerDate: 12/01/2021

Sample Location Description	Sample Location Code	Date	Time	Duration of Flushing	Reason for Flushing
Main Building 1 st Floor Girl's Room Left Sink	01	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Main Building 1 st Floor Girl's Room Left Sink 30 Second Flush	02	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Main Building 1 st Floor Girl's Room Right Sink	03	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Main Building 1 st Floor Boy's Room Middle Sink	04	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Main Building 1 st Floor Staff Bathroom	05	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Main Building 1 st Floor Bottle Water Fountain	06	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Main Building 1 st Floor Cafeteria Bottle Water Fountain	07	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Main Building 1 st Floor Multipurpose Room Bottle Water Fountain	08	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Main Building 1 st Floor Kitchen Food Prep Sink	09	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling

Beloved Community Charter School Sampling Plan

Date: 12/01/2021

Main Building 1 st Floor Kitchen Handwashing Sink	10	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Main Building 2 nd Floor Girl's Room Middle Sink	11	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Main Building 2 nd Floor Staff Bathroom Sink	12	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Main Building 2 nd Floor Boy's Room Left Sink	13	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Annex 3 rd Floor Bottle Water Fountain	14	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Annex 3 rd Floor Girl's Bathroom Right Sink	15	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Annex 3 rd Floor Boy's Bathroom Left Sink	16	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Annex 3 rd Floor Staff Bathroom Sink	17	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Annex 2 nd Floor Girl's Bathroom Left Sink	18	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Annex 2 nd Floor Bottle Water Fountain	19	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Annex 2 nd Floor Boy's Bathroom Left Sink	20	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Annex 1 st Floor Girl's Bathroom Right Sink	21	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Annex 1 st Floor Boy's Bathroom Right Sink	22	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Annex 1 st Floor Cafeteria Water Fountain	23	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling
Annex 1 st Floor Kitchen Food Prep Sink	24	11/22/2021	3:00 pm	2-3 Minutes	Water Sampling

Attachment F - Pre – Sampling Water Use Certification

TO BE COMPLETED BY THE BELOVED COMMUNITY CHARTER SCHOOL REPRESENTATIVE:		
School Name: <u>Beloved Community Charter School</u>		
Sample collection address:	508 Grand Street, Jersey City, New Jersey 07302	
Water was last used:	Time: 3:00 PM	Date: 11/22/21
Sample commencement:	Time: 7:00 AM	Date: 11/23/21
I have read the Lead Drinking Water Testing Sampling Plan and Quality Assurance Project Plan and I am certifying that samples were collected in accordance with these plans.		
Duanne Moeller	12/01/2021	
Signature	Date	

Attachment G - Example of a Sample Flush Tag

FLUSH TAG

Water outlet sampling in progress. Please do not use water

School District Name: Little Seaters Day Care Pre-School Date Flushed:
School Name: Flushing Process
School Address: Start Time:
Location of flushed outlet: End Time:

Is the fountain front cover removed for the sampler to determine the reservoir type (circle one):
YES / NO

Person responsible for the flushing process (print name): _____

Signature: _____

* Water within the school distribution system should sit in the pipes unused for at least eight (8) hours after flushing but not more than 48 hours before a sample is taken.*

Note to the person responsible for the flushing process:

- A. Turn-off lawn sprinkler outlet(s) until water sampling is complete.
- B. Make sure sampling outlets are accessible.